



Material Approval Request (MAR) Form

Document Ref. No. 70933-MAT-S600000-000001(1)

Date: 28 Sep 2020 Confidential Yes No

Project Name	EXPO SERVICE PAVILION	Project Reference No.	S60- 5282
Contract No.	70933	Contract Title	Expo Service Pavilion
Contractor Name	ISG Middle East LLC	Inspection Request No.	Inspection Req. No.

Material Details

Name	Model Number	Supplier/Sub contractor
GI CONDUITS AND ACCESSORIES	Various	M/s Gedac Emirates / Al Futtaim
Manufacturer	Country of Origin	Sample Location
ITCC	KSA	NA
Description	Drawing Reference	Specification
GI CONDUITS AND ACCESSORIES	Various	26 0519 – 1

Attachments	Yes/No	Comments
Related IFC Drawings (or Standard Drawing from Authority/s), Specifications and BOQ	Yes	Attached
Technical Literature/Data Sheet	Yes	Attached
Material/Lab Test Certificate	No	Attached
Previous Test Results	Yes	Attached
ISO 9001, ISO 14001 & OHSAS 18001 Certificates	Yes	Attached
Trade or Commercial Licence	Yes	Attached
Certificate of Compliance (For Individual Material)	Yes	Attached
Compliance Statement (For Final/Finished Product)	No	Attached
Sustainability Standard Certificate/Questionnaire	Yes	Attached
Environmental Product Declaration (For Steel and Concrete only)	No	NA
Chain of Custody Certificate (For Timber)	No	NA
Social and Environmental Policies	Yes	NA
Fire Fighting Certificate (For Exposed Material)	No	NA
Material Safety Data Sheet (MSDS)	No	NA



Document Ref. No. 70933-MAT-S600000-EL-000001(1)

Date: 28 Sep 2020 Confidential Yes No

Previous Authority Approval	Yes	Attached
Details of Warranty	Yes	Attached
Others	No	Company Profile Attached.

Note:

- The requirements of above supporting documents shall be reviewed in accordance with the contract’s technical specifications and the programme Assurance Minimum Standards. Where other supporting documents are required but not in the list, it shall be provided under “Others”.
- The material submission shall be to the satisfaction of the engineer that the material offered is equal or superior to and fully comply with the material specified in the contract’s technical specification. If full supporting documentation is not available at the time of submission, the contractor shall indicate on this form when the respective documentation will be available for formal submission to the engineer.
- The material approval process is explained in the PMDS Activity Guide - Material Submission (Ref. 05007-ATG-P990000-QL-000004).

Contractor’s Comment(s) or Additional Notes, if any.

Click here to enter text.

To Be Completed By the Engineer

Reviewer Name	Position	Comments	Signature	Date
Ali Obeid	Electrical Engineer	Refer to the below technical comments	A.O.	30-09-2020



Document Ref. No. 70933-MAT-S600000-EL-000001(1) Date: 28 Sep 2020 Confidential Yes No Approver Name

Position	Comments	Signature & Stamp	Date
Fouad Gattas		MEP Manager	Approved as noted.
Gary White		Snr Res Eng	Refer to MEP Eng Comments
			FG
			30-09-2020
			06-10-20

Engineer's Comments

Technical Comments:
 The material of GI conduits, boxes and accessories manufactured by ITCC (KSA) and supplied by M/s Gedac Emirates is acceptable subject to comply with the following points:
 1- Surface conduits shall be heavy gauge hot dipped galvanized class 4 manufactured in accordance with BS4568 part 1.
 2- Size of conduits, boxes & accessories to be in compliance with the number and size of wires in accordance with Dewa wiring regulations.
 3- Samples to be submitted.

Compliance against the Programme "Assurance Minimum Standards – Sustainability":

Full Compliant
 Part Compliant – Reasons: Specify here.
 Not Compliant – Reasons: Specify here.

Material Approval Status:

Approved
 Approved with Comments (Refer Engineer's Comments Above)
 Rejected