

MC - SH  
26.11

KING ABDULLAH FINANCIAL DISTRICT

**MATERIAL SUBMITTAL FORM**

Contract No: DB16CZ2      Work Package: DB16CZ2  
 Title: EMT Conduits      Submittal Number: DB16CZ2-MT-E-104      Rev: 2  
 From: Saudi Binladin Group      Submittal Package: Electrica  
 To: Dar Al-Riyadh      Date: 17/Nov/2011      No. of Copies: 5  
 Attn: Dar Al-Riyadh

**MATERIAL DESCRIPTION**

Material Status: Specified     Alternative  
 Discipline: ( E ) ELEC      Drawing Ref.:  
 Specification: 16140 - Part. 2.02  
 Parcel No: General      Building: All      BOQ Ref. No.:  
 Enclosures: Catalogue    Sample    Comparison Sheet    Production Verification    List of Suppliers     Other  
 Remarks: Compression type EMT Fittings are already approved through submittal ref.DB16CZ2-MAT-E-014 Rev.02 and DB16CZ2-MAT-E-070 Rev.01

**MANUFACTURER / SUPPLIER**

Company Name: ITCC      Local Agent: Electric House.  
 Address:

**DELIVERY**

Country of Origin: KSA      Availability:  Locally Available    Imported  
 Delivery Program :  
 Ex-Work Total Duration: 0      Latest Date of Order:  
 Date Material Required on Site:      Estimated Date for Arrival on Site:  
 certify that the above submitted items have been reviewed in detail and are correct and in strict conformity with the contract drawings and specifications except otherwise stated; also that the material sources indicated above have been reviewed and that they will supply the submitted items in full conformity with timely delivery

**For the Contractor :**

Name: Fraih Haddad      Signature: *[Signature]*      Date: 19-11-2011


**CONSULTANT'S COMMENTS**

Approved as commented in the attached sheet.

Name: *Amar Arum*      Signature: *[Signature]*      Date: *11*

**Approval Code**

Approved       Approved As Noted  
 Rejected - Resubmit      Receipt Acknowledged



**PM / SMT REVIEW**

Name: .....      Signature: .....      Date: .....

**OWNER'S COMMENTS (Optional)**

Name: .....      Signature: .....      Date: .....

Approval shall not relieve the contractor of its obligations and liabilities under the Contract or constitute authorization of any change to Contract Documents, and therefore, shall not imply any recognition whatsoever of additional time or cost to the Contract.

<b>Distribution</b>				<b>To Contractor</b>	
Owner	PM / SMT	Engr/Const	Contractor	RECEIVED	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Date:	<i>[Signature]</i>
RECEIVED DOCUMENT CONTROLLER UPP 03 DEC 2011 ZONE:				24 NOV 2011 ZONE - 2 (PPA)	

KING ABDULLAH FINANCIAL DISTRICT-PPA 30




Material Submittal: Comments on :  
EMT Conduit & Fittings by ITCC /Electric House


Contract No: PPA30		Work Package No: DB16CZ2	
Submittal No	DB16CZ2-MT-E-104(Rev.2 )	Date:30/11/11	Status Code: B

Comments:

1. EMT Conduit And Fittings shall comply to project specification and NEC article 348 requirements.
2. Attached documents, compliance statement, compliance certificate(Fittings), warranty letter are sufficiently enough to support quality assurance of materials.
3. Submit complete sample of conduit & fittings.
4. Name, address & origin of the product more especially the fittings shall be mention in the documents.

  
Sr. Elect. Engineer  
Moises Carrilano

  
Sr. Elect. Engineer  
Syed Hussain Ali

  
30.11.11  
Molham M. Samsam  
ARE MEP  
KAFFD-PPA30

