



DC PRO SUBMITTAL RESPONSE SHEET

Discipline: Electrical
Job/ Contract No.: Apollo 3 Data Center
Document Title: MATERIAL SUBMITTAL FOR ITCC FLEXIBLE CONDUITS AND ACCESSORIES
Document No.: HWI-APO3-EL-MTS-0027-00
Issued To : HUAWEI **Received Date** September 9, 2020

S/N	Comments	Status	Issued Date	Signature
		B	September 14, 2020	Ahmad
1	Conduit sizes and accessories shall be selected as per approved shop drawings			
2	All materials and accessories shall be from the same supplier. Conduits and related accessories shall be of the same finish			
3	Ensure proposed flexible GI conduits are liquid tight.			
4	Flexible GI conduit size, length, type and area of application shall be as per final approved shop drawings and in line with ADDC regulations			
5	Installation of conduits shall be as per manufacturer recommendation and in line with ADDC regulations			
6	Subject to ADDC Approval			

Status	A	-	Approved with No Comments.
Status	B	-	Approved with Comments. Contractor may proceed ensuring comments are addressed and incorporated. No resubmission is required.
Status	C	-	Revise and Resubmit. Contractor may not proceed. Contractor to resubmit incorporating comments.
Status	D	-	Rejected. No further resubmission is required.