



| TRANSMITTAL FORM | | | |
|---|----------------------|---|--------|
| Location | | Transmittal No. | |
| <input type="checkbox"/> Alanso <input type="checkbox"/> Dammam <input type="checkbox"/> Haif <input type="checkbox"/> Jeddah <input type="checkbox"/> Medina <input type="checkbox"/> Qassim <input type="checkbox"/> Yanbu <input type="checkbox"/> Taif <input type="checkbox"/> SANG Office <input checked="" type="checkbox"/> All <input checked="" type="checkbox"/> Soldier Villa <input checked="" type="checkbox"/> Officer Villa <input type="checkbox"/> External Works <input type="checkbox"/> Others | | TR-2371 | |
| Type of Transmittal | | Rev. 0 | |
| <input checked="" type="checkbox"/> Material <input type="checkbox"/> Drawing <input type="checkbox"/> Document | | Date: 16-Dec-12 | |
| SO / OV/ EWT / GWT / IWT / STP | | Specification | |
| <input type="checkbox"/> Arch. <input type="checkbox"/> Civil <input type="checkbox"/> Str. <input checked="" type="checkbox"/> Elec. <input type="checkbox"/> Mech. <input type="checkbox"/> T. <input type="checkbox"/> PL. <input type="checkbox"/> BW. | | Volume - 16, Section 16415, Page # 20/48 | |
| EW | | SUB NO: MAT-GEN-E0051 | |
| <input type="checkbox"/> WW <input type="checkbox"/> TR <input type="checkbox"/> DR <input type="checkbox"/> LS <input type="checkbox"/> MV <input type="checkbox"/> IR <input type="checkbox"/> UD <input type="checkbox"/> LV <input type="checkbox"/> T <input type="checkbox"/> SW <input type="checkbox"/> STL | | | |
| ITEM | Reference | Description | Action |
| 1 | Rigid Metal Conduit | Rigid Conduit With Fittings (for Outdoor Application) | |
| A | GI Conduit RB-1-2013 | Manufacturer: ITCC Country of Origin: Kingdom of Saudi Arabia | |
| B | Coupler | Manufacturer: ITCC Country of Origin: Kingdom of Saudi Arabia | |
| B | Fittings | Manufacturer: Cooper Crouse - Hinds Country of Origin: India | |
| | | Supplier: Electric House EST. Country Of Origin: Kingdom of Saudi Arabia, Jeddah | |
| | | Area of Application: Rigid Conduit With Fittings (EXTERNAL WORK) in Soldiers & Officers Villa. | |
| 2 Set of hard Copies & Soft Copy & Sample | | | |
| For Saudi Bin Ladin Group | | Technical Manager | |
| Checked By: (QA/QC) / PE Signature: Date: | | Signature: 12-16-12 | |
| For Consultant use / لاستعمال المكتب الاستشاري | | | |
| REMARKS: | | | |
| - No objection on the proposed (UL) material subject to contract condition. MAJ 05/01/2013 - Fittings must be matching to conduiting system. 29.01.2013 | | | |
| <input type="checkbox"/> See Attached Comments Engineer Signature: Date: 27.1.2013 | | <input type="checkbox"/> See Comments on Drawings Project Manager Signature: Date: 28/1/2013 | |
| For SANG use / لاستعمال الحرس الوطني | | | |
| REMARKS: | | | |
| <input type="checkbox"/> See Attached Comments Engineer Signature: Date: | | <input type="checkbox"/> See Comments on Drawings Project Manager Signature: Date: | |
| هذه الموافقة لا تخلص المقاول من مسؤوليته حسب متطلبات العقد | | | |
| A: Approved. B: Approved as Noted. C: Revise and Resubmit. D: Not Approved. E: Returned without action, F: informed | | | |



دار الرياض
DAR AL RIYADH



مجموعة بن لادن السعودية
SAUDI BINLADIN GROUP



SUBMITTAL FOR APPROVAL OF MATERIALS

Project Name : National Guard Housing Project Contractor : Saudi Binladin Group Contract No. : P1220
 Owner Representative : AAW, Partners and DAR AL Riyadh Owner : National Guard Technical Affairs
 Location : General Al Hasa Al Dammam Hail Jeddah
 Madina Qassim Yanbu Taif
 Solider Villa Officer Villa External Works Others
 Title : Itcc-Rigid Conduit With Fittings (f Transmittal No. : TR-2371
 Submittal No. : MAT-GEN-E0051 Rev. No. : 00 No of Copies : 2 Date : 12/16/2012

TO : OWNER REPRESENTATIVE

We request the Owner Representative's approval on the following Materials

1- MATERIAL DESCRIPTION (One item only on this form) Type of Material : Electrical

Area of Application : Rigid Conduit With Fittings (EXTERNAL WORK) in Soldiers & Officers Villa.

Drawing Ref. : BOQ Ref. No. :

Specification : Volume - 16, Section 16415, Page # 20/48 Standards :

Enclosures : 2 Hard Copies + CD + Sample Document No. :

Attach all relevant technical literature marked to identify relevant description, current test certificates, samples as appropriate.

28-1-2013

| | |
|--------------------------|----------------------------|
| <input type="checkbox"/> | Approved - As Submitted |
| <input type="checkbox"/> | Approved - Except As Noted |
| <input type="checkbox"/> | Revise - Resubmit |
| <input type="checkbox"/> | Disapproved - Resubmit |
| <input type="checkbox"/> | Receipt - Acknowledged |

2- MANUFACTURER/SUPPLIER

Company Name : ITCC , Cooper Crouse - Hinds Vendor No. : AAE

Address :

Local Agent : Electric House EST.

Listed in Approved Project Vendor's List

3- DELIVERY

Country of Origin : KSA,INDIA

Availability : Overseas

Delivery Program : Ex-works/ Total Duration :

Estimated Date of Arrival on Site :

Date Material Required on Site :

Latest Date for Order :

FOR THE CONTRACTOR

QA/QC Manager / PE [Signature]

Technical Manager [Signature] 12-16-12

For Consultant use | لاستعمال المكتب الاستشاري

Refer to transmittal sheet for comments

28-1-12

For National Guard Technical Affairs use | لاستعمال الحرس الوطني

[Signature]

Action Code Legend:

A: Approved As Submitted

B: Approved - Except As Noted

C: Revise - Resubmit

D: Disapproved - Resubmit

E: Receipt Acknowledged

FOR : THE OWNER REPRESENTATIVE

Name : MAS

Signature : [Signature]

Date : 29.01.2013