

PROJECT: DOWNTOWN VIEWS II

EMAAR

CLIENT :	EMAAR DEVELOPMENT PJSC
ENGINEER:	ARCHGROUP
MAIN CONTRACTOR:	CHINA STATE CONSTRUCTION ENGINEERING CORP. ME.LLC
SUB CONTRACTOR:	



MATERIAL APPROVAL SHEET (MAS)

Planned Submission Date : March 25, 2019		Actual Submission Date: March 25, 2019	
Submittal No. DTVII-CSC-E-MAS-017	Rev. 00	Date: March 25, 2019	
Sample Tag Ref No. DTVII-CSC-E-SAM-018	Rev. 00	Date: March 25, 2019	
Previous Submittal Ref No. N/A	Rev. N/A	Date: N/A	
Originator : China State Construction Engineering Corp.ME.L.L.C	Sign of Originator :		

[] ARCH. [] STR. [X] ELECT. [] MECH.

SUB-CONSULTANT :

- () ID. () LANDSCAPE. () FAÇADE. () FIRE & LIFE SAFETY. () VT. () IT AV.
 () SIGNAGE & WAY FINDER. () LIGHTING. () POOL & WATER FEATURE. () SECURITY ACCESS.
 () ACOUSTIC DESIGN. () GREEN BUILDING. () OTHERS

Item Description	RIGID AND FLEXIBLE GI CONDUITS & ACCESSORIES	(Tick the Related Box)
Specs. Reference	26-05-33	<input type="checkbox"/> Vendor's Technical Literature
BOQ Reference	Bill No. 9.5 Electrical Installation	<input checked="" type="checkbox"/> Compliance Statement
Drg. Reference	All Electrical Layouts	<input checked="" type="checkbox"/> Previous Test Results
Material Specified/ Country of Origin	RIGID AND FLEXIBLE GI CONDUITS & ACCESSORIES	<input checked="" type="checkbox"/> Copy of the Related Specs.
	N/A	
Material Proposed/ Country of Origin	RIGID AND FLEXIBLE GI CONDUITS & ACCESSORIES	<input checked="" type="checkbox"/> List of Previous Projects Done
	UAE	
Manufacturer/ Local Supplier	INTERNATIONAL TUBE AND CONDUIT COMPANY LTD. / HAJI COMMERCIAL COMPANY LLC	<input checked="" type="checkbox"/> Samples
Reason for Alternative	N/A	<input type="checkbox"/> Guarantee
GBR	Not Required	<input type="checkbox"/> Green Building Compliance required
Remarks/Location	Downtown Views II, Dubai UAE	<input type="checkbox"/> Others (specify)

Main Contractor's Statement

We certify that the material submitted herewith has been reviewed in detail and is in full compliance with the contract drawings, design requirement and specifications except as otherwise stated here above. The material submission shall be to the satisfaction of the Engineer that the material offered is equal or superior to and fully complies with the material specified in the contract's technical specification.

Main Contractor Signature :

Date : 25/03/19

Sub-Consultant- _____ Comments :

Refer to comments provided on attached comments sheet and comply.



25/03/19

ARCHGROUP Comments :

1. Proposed 'GI Conduit' shall be fully 'Hot Dip Galvanized ie internally & externally both.

STATUS of Approval :

Status A	Status B	Status C	Status D
Approved	Approved As Noted	Revise & Resubmit	Rejected

Project Coordinator	MEP Manager  03-04-19	Resident Engineer 
---------------------	--	---

ENGINEER PROJECT DIRECTOR :

Employer's Consent Required (Review by exception only): [] Yes [] No

Emaar MEP : Material Recommended / Rejected

- 1. No objection to the proposed conduit ensures the latest BS mark 61386 part 21 on the product delivery with proper GI thickness tested from the certified labs ensure to comply with all accessories GI conduit shall be used in the parking and plant areas.
- 2. Exposed installation and other ceiling void area any exposed conduits (missed out from concealed) shall be proposed with LSOH conduit for the easy installation and coordination at site. Relevant cost saving if any shall be evaluated accordingly by QS separately.

Emaar Security / IT: Material Recommended / Rejected

Other Emaar Departments: Material Recommended / Rejected

Emaar Development Director : Material Recommended / Rejected

Corrections or comments made relative to submittals during this review do not relieve the Contractor from compliance with the Contract requirement's, specifications and design concept. This check is for review of general project requirements only.

Main Contractor Received: Date & Sign	
--	--

Document Reference: DTVII-CSC-E-MAS-017 Rev.00

Status: "B" Approved as Noted





Comments:

1. Proposed material "ITCC" by (M/s Haji Commercial Company LLC" for "Rigid and Flexible GI conduit @ Accessories" is technically accepted.
2. Provide water Tight adaptor for wet areas. Submit Catalogue data sheet and sample for the engineer review and approval.
3. Submit catalogue data sheet and sample for Expansion Joint area fittings for the engineer review and approval
4. Provide Factory test reports to confirm HDG coating thickness along with each delivery of items. The same shall be attached with MIR. Failing of providing these documents will result to reject the material.
5. Submit method statement for installation prior proceeding related work at site.



03-04-19


PROJECT: DOWNTOWN VIEWS II

	EMPLOYER:	EMAAR DEVELOPMENT PJSC		
	ENGINEER:	ARCHGROUP		
	MAIN CONTRACTOR:	CHINA STATE CONSTRUCTION ENGINEERING CORP. ME.LLC		
	SUB CONTRACTOR:			
SAMPLE TAG				
Submittal No. DTVII-CSC-E-SAM-018		Rev. 00	Date: March 25, 2019	
Material Submittal Ref. No. DTVII-CSC-E-MAS-017		Rev. 00	Date: March 25, 2019	
Previous Submittal Ref No. N/A		Rev. N/A	Date: N/A	
Originator : China State Construction Engineering Corp.ME.L.L.C		Sign of Originator : 		

We are sending herewith the Material Samples as listed below:

Material Description: RIGID AND FLEXIBLE GI CONDUITS & ACCESSORIES			
Location to be used :		Downtown Views II, Tower 1, 2 & 3	
Item No.	Description	Manufacturer / Supplier	No. of Samples
1	RIGID CONDUIT 25MM	INTERNATIONAL TUBE AND CONDUIT COMPANY LTD. / HAJI COMMERCIAL COMPANY LLC	1
2	TEE THREE WAY CIRCULAR BOX	INTERNATIONAL TUBE AND CONDUIT COMPANY LTD. / HAJI COMMERCIAL COMPANY LLC	1
3	INTERSECTION FOUR WAY CIRCULAR BOX	INTERNATIONAL TUBE AND CONDUIT COMPANY LTD. / HAJI COMMERCIAL COMPANY LLC	1
4	THROUGH TWO WAY CIRCULAR BOX	INTERNATIONAL TUBE AND CONDUIT COMPANY LTD. / HAJI COMMERCIAL COMPANY LLC	1
5	CIRCULAR BOX COVER	INTERNATIONAL TUBE AND CONDUIT COMPANY LTD. / HAJI COMMERCIAL COMPANY LLC	1
6	COUPLING	INTERNATIONAL TUBE AND CONDUIT COMPANY LTD. / HAJI COMMERCIAL COMPANY LLC	1
7	MALE BUSH LONG	INTERNATIONAL TUBE AND CONDUIT COMPANY LTD. / HAJI COMMERCIAL COMPANY LLC	1
8	HEXAGONAL LOCKNUT	INTERNATIONAL TUBE AND CONDUIT COMPANY LTD. / HAJI COMMERCIAL COMPANY LLC	1
9	LSOH COATED FLEXIBLE CONDUIT	INTERNATIONAL TUBE AND CONDUIT COMPANY LTD. / HAJI COMMERCIAL COMPANY LLC	1
10	BRASS NICKEL PLATED ADAPTOR	INTERNATIONAL TUBE AND CONDUIT COMPANY LTD. / HAJI COMMERCIAL COMPANY LLC	1
11	3" X 3" METAL CLAD BOX	INTERNATIONAL TUBE AND CONDUIT COMPANY LTD. / HAJI COMMERCIAL COMPANY LLC	1

12	3" X 6" METAL CLAD BOX	INTERNATIONAL TUBE AND CONDUIT COMPANY LTD. / HAJI COMMERCIAL COMPANY LLC	1
13	SPACER BAR SADDLE	INTERNATIONAL TUBE AND CONDUIT COMPANY LTD. / HAJI COMMERCIAL COMPANY LLC	1
14	DISTANCE SADDLE	INTERNATIONAL TUBE AND CONDUIT COMPANY LTD. / HAJI COMMERCIAL COMPANY LLC	1



Main Contractor	
Name	Walid Saad
Signature	
Date	25/03/19

Engineer Comments :

1- Refer to comments provided on material submittal and comply.
 2- Submit additional sample required as indicated in comments.

STATUS of Approval :

Status A	Status B	Status C	Status D
Approved	Approved As Noted	Revise & Resubmit	Rejected

Project Coordinator	MEP Manager  03-04-19	Resident Engineer 
ENGINEER PROJECT DIRECTOR :		

Employer's Consent Required [] Yes [] No (Review by exception only):

Emaar MEP : Material Recommended / Rejected

Emaar ID : Material Recommended Rejected

Material Recommended / Rejected

Received by the Contractor: _____

Date: _____



ITCC Pipe & Conduit Company Ltd.

LEADING EDGE IN TUBE TECHNOLOGY

TEE THREE WAY CIRCULAR BOX

DISTANCE SADDLE

SPACER BAR SADDLE

THROUGH TWO WAY CIRCULAR BOX

CIRCULAR BOX COVER

INTERSECTION FOUR WAY CIRCULAR BOX

COUPLING

MALE BUSH LONG


3" X 3" METAL CLAD BACK BOX

3" X 6" METAL CLAD BACK BOX

LSOH COATED FLEXIBLE CONDUIT

ITCC RIGID CONDUIT 25MM BS4568:1970 CLASS 4 HDG MADE IN KSA

RIGID CONDUIT 25MM



sales@itcc-group.com