






## MATERIAL APPROVAL REQUEST

<b>The Engineer:</b>  <b>TUBAILA TEAM WORKSHOP</b> شركة العمارة والاستشارات الهندسية ARCHITECTURE   ENGINEERING   CONSTRUCTION MANAGEMENT	<b>The : Employer:</b> 	<b>The Contractor:</b>  شركة الخطيب المتحد للتجارة والمقاولات Al-Khateeb United Trading & Contracting Co.	
Project Name	<b>Ibn Al-Haitham Service station</b>	Request No.:	IHSS-MA-025-00
The Employer	<b>Tas'helat Marketing (TMC)</b>	Date:	12\04\2022
The Engineer	<b>Arab Sustainable Architecture for Engineering / TTW</b>	Time:	
The Contractor	<b>Khateeb United Trading &amp; Contracting Co.</b>		
Contract No.	<b>003/2021</b>		
To : <b>The Engineer</b>		From : <b>The Contractor</b>	
<b>1 Material Description:</b>			
Item Description:	ELECTRIC METALIC TUBING		
Model:	ITCC		
Area Of Application :	multible building		
Drawing ref:	E2 E-201 , E1 E-101, E3 E-301	B.O.Q ref.:	26, 27 ,28
Specifications ref :	26 05 33		
Attach all relevant technical data marked to identify relevant description.			
<b>2 Manufacture / supplier :</b>			
Company Name:	ITCC		
Address:	DAMMAM		
Local Agent:	al abdulkarim holding company AKH		
<b>3 Delivery:</b>			
Country of origin:	KSA		
Availability :	<input checked="" type="checkbox"/> Locally Manufactured	<input type="checkbox"/> Imported	
Delivery:	Ex- Works/ Total Duration:	EX stock	
	Estimated time of arrival on site:	6-8 weeks from PO	
Schedule:	Date material required on site	N/A	
	Latest date for order	N/A	
For : Contractor (Name)	Eng.Mohammad Elrefai	Signature :	
Received on (Date) :	Time :		
Name:	Signature:	Date:	
<b>4 For The Engineer Use:</b>			
<input type="checkbox"/> Approved	<input checked="" type="checkbox"/> Approved as noted	<input type="checkbox"/> Revise and resubmit	<input type="checkbox"/> Rejected
<input type="checkbox"/> Sample required	<input type="checkbox"/> Tests required	<input type="checkbox"/> Additional information	<input type="checkbox"/> Manufacturer's guarantee
Remarks : 1.Special items for 90° - Galvanized Steel to be provided instead of elbows to be provided.			
2.Size of conduits refer to drawings & project specs			
			
Name:	Signature:	Date: 16.4.2022	
THE ABOVE DOES NOT RELIEVE THE CONTRACTOR FROM HIS OBLIGATIONS AS PER CONTRACT AND SPECIFICATION			