






MATERIAL APPROVAL REQUEST

The Engineer:  TUBAILA TEAM WORKSHOP شركة العمارة المستدامة العربية للإستشارات الهندسية ARCHITECTURE ENGINEERING CONSTRUCTION MANAGEMENT	The : Employer: 	The Contractor:  شركة الخطيب المتحد للتجارة والمقاولات Al-Khateeb United Trading & Contracting Co.	
Project Name	Ibn Al-Haitham Service station	Request No.:	IHSS-MA-025-00
The Employer	Tas'helat Marketing (TMC)	Date:	12\04\2022
The Engineer	Arab Sustainable Architecture for Engineering / TTW	Time:	
The Contractor	Khateeb United Trading & Contracting Co.		
Contract No.	003/2021		
To : The Engineer		From : The Contractor	
1 Material Description:			
Item Description:	ELECTRIC METALIC TUBING		
Model:	ITCC		
Area Of Application :	multiple building		
Drawing ref:	E2 E-201 , E1 E-101, E3 E-301	B.O.Q ref.:	26, 27 ,28
Specifications ref :	26 05 33		
Attach all relevant technical data marked to identify relevant description.			
2 Manufacture / supplier :			
Company Name:	ITCC		
Address:	DAMMAM		
Local Agent:	al abdukarim holding company AKH		
3 Delivery:			
Country of origin:	KSA		
Availability :	<input checked="" type="checkbox"/> Locally Manufactured	<input type="checkbox"/> Imported	
Delivery:	Ex- Works/ Total Duration:	EX stock	
	Estimated time of arrival on site:	6-8 weeks from PO	
Schedule:	Date material required on site	N/A	
	Latest date for order	N/A	
For : Contractor (Name)	Eng.Mohammad Elrefai	Signature :	
Received on (Date) :	12-Apr-22	Time :	
Name:	Saif AbuRabia	Signature:	<i>Saif</i>
		Date:	12-Apr-22
4 For The Engineer Use:			
<input type="checkbox"/> Approved	<input checked="" type="checkbox"/> Approved as noted	<input type="checkbox"/> Revise and resubmit	<input type="checkbox"/> Rejected
<input type="checkbox"/> Sample required	<input type="checkbox"/> Tests required	<input type="checkbox"/> Additional information	<input type="checkbox"/> Manufacturer's guarantee
Remarks : 1.Special items for 90° - Galvanized Steel to be provided instead of elbows to be provided.			
2.Size of conduits refer to drawings & project specs			
			
Name:	Saif AbuRabia	Signature:	<i>Saif</i>
		Date:	17.4.2022
THE ABOVE DOES NOT RELIEVE THE CONTRACTOR FROM HIS OBLIGATIONS AS PER CONTRACT AND SPECIFICATION			