

**New King Abdullah Bin Abdulaziz International Airport, Jazan**

|      |                      |  |                   |    |      |                  |      |    |
|------|----------------------|--|-------------------|----|------|------------------|------|----|
| Date | 29-May-2021          | Document Type                              | Transmittal No    |    |      |                  |      |    |
|      |                      |  | PRE-QUALIFICATION |    |      | PQP-PROC-EL-0052 | Rev  | 00 |
| To   | SAUDI DIYAR          | Transmittal Title                          | Department        |    |      |                  |      |    |
|      |                      |  | QAQC              | QS | Tech | Proc             | Cons | PC |
| From | SAFARI               | IMC, FLEXIBLE METAL & LIQUIDTIGHT CONDUITS | Discipline        |    |      |                  |      |    |
| For  | Approval Information |  | CW                | SU | ST   | AR               | EL   | ME |

| Item No. | Discipline | Item Description<br>(Name, Type, Size, Capacity, Specific Use, Etc.) | Firm                  | Doc. Ref. (Catalog Ref., Brochure) | Rev. | No. of Copies |
|----------|------------|--|-----------------------|------------------------------------|------|---------------|
| 1        | ELEC       | IMC, Flexible Metal & Liquidtight Conduits - FAHEEM BAKHSH TRADING   | FAHEEM BAKHSH TRADING | N/A                                | 00   | 03            |

|                     |                      |              |                 |
|---------------------|----------------------|--------------|-----------------|
| Department Head     | SAFARI               | SAFARI       | Attachments     |
| <i>Ahmed Souplh</i> |                      |              | Items Qty       |
| Date                | Signature            | Submit Stamp | Receiving Stamp |
| Project Director    | <i>Mousa Al Gara</i> |              | Hardcopy 3      |
| Date                | Signature            |              | Softcopy 3      |
|                     |                      |              | Ref Doc         |


| Item # | Code | Action Code | Remarks:   |
|--------|------|-------------|--|
| 1      | 2    | 2.B         | a) Installation shall only proceed when Action Code is 1 or 2.   |
|        |      | 1.A         | b) Action Code 3 shall be resubmitted within time limit set in the contract  |
|        |      | 3.C         | c) Review does not relieve the Contractor from Responsibility of Compliance with all requirements of contract documents. |
|        |      | 4.D         | d) Transmittal shall be considered CLOSED on 1.A, 2.B, 4.D & 5.E and OPEN on 3.C   |
|        |      | 5.E         |  |

**SDC Comments**

\* Refer to our site staff Comments.



|  |            |      |      |                   |             |           |
|--|------------|------|------|-------------------|-------------|-----------|
| <b>DIYAR</b><br>30 MAY 2021<br><b>RECEIVED</b> | DISCIPLINE | NAME | SIGN | Resident Engineer | Attachments |           |
|  | SURVEY     |      |      |                   |             | Items Qty |
|  | CIVIL      |      |      |                   |             |           |
|  | ELEC       | A-R  |      |                   |             |           |
|  | MECH       |      |      |                   |             |           |
| Date/Time                                      | Stamp      |      |      | Date:             |             |           |



## Site Staff Comments

Page 1

Subject: FAHEEM-BAKHSB TRADING- Pre-qualification for IMC , FLEXIBLE METAL & LIQUIDTIGHT CONDUITS AND FITTINGS

Received Date 29-May-2021

Issued Date:20-06-2021

Contractor: SAFARI

Project Title: New King Abdul-Aziz International Airport, Jazan

Project No.: JZS - 1440

Attachments: Document - Pre-Qualification (FAHEEM BAKHSB TRADING.)

Trans. Number: PQP-PROC-EL-0052 Rev. 00

Date:20-06-2021

Design drawings, specification, and site requirements have been used in the review with the following conducted remarks:-

| Item | Comments   | Recommended Code |
|------|--|------------------|
| 1    | A supplier profile must be provided on attached file .   | 2                |
| 2    | Gosi certificate must be update .  |                  |
| 3    | The short-term warranty certificate is only 12 months, it should include manufacturing and supply,so the warranty certificate should be longer.                                  |                  |
| 4    | IMC test certificate must be attached to the profile of the manufacturer ITCC .  |                  |
| 5    | The supplier must have a ware house at which spare parts and stocked .   |                  |
| 6    | The ITCC manufacturer must submit a company file with all approved government certificates.  |                  |
| 7    | Complete Cataloges have to be submitted for IMC , FLEXIBLE METAL & LIQUIDTIGHT CONDUITS AND FITTINGS   |                  |
| 8    | Any commercial impact related to relevant technical comments issue should be promptly raised by the contractor for review and client approval prior to proceeding of next stage. |                  |
| 9    | This code B Approval doesn't relieve the contractor for Any obligation under the contract and is independent of any future review and submitted approved design.                 |                  |
| 10   | samples should provided with the submission of the material transmittal .  |                  |

Name: FERAS AWWAD

Signature : \_\_\_\_\_

Date : 20-06-2021

SDC- Electrical Head

F-CS09/A

