

Submittal for approval of materials

Date: 5th June 2018

Request no: EBB-CAR0-ELE-PIPES-002-1.0

Project no. & title: **Upgrading and Expansion of Entebbe International Airport Project**

Employer: 	Engineer:  Dar At-Hamdanah Shair and Partners 05 JUN 2018 RECEIVED	Contractor: 
---	---	---

1. Material description (one item only on this form) :
 Rigid steel conduits and fittings

Area of application : Cargo Building

Drawing ref. : ELE DD of Cargo B.O.Q. ref. no.:

Specification Ref. : 71973-ELE-SPE-000-014_1.0 Standards: BS 4568, BS EN 50086

Attach all relevant technical literature marked to identify relevant description, current Test Certificates, samples as appropriate.

2. Manufacturer / supplier

Company Name : ITCC

Address : Jeddah 21433 kingdom of Saudi Arabia

Local agent : /

3. Delivery :

Country of origin : Saudi Arabia

Availability Locally Manufactured Overseas

Delivery : Ex-works/ total duration [30 Days] [90 Days]

Estimated time of arrival on site [10th August 2018]

Program : Date material required on site [20th August 2018]

Latest date for order [15th August 2018]

We certify that the above submitted items have been reviewed in detail and are correct and in strict conformity with the contract drawings and specifications except as otherwise stated; also that the material sources indicated above have been reviewed in detail and that they will supply the submitted items in conformity with the above and deliver same timely.

Submitted by: Nancy Shaei Signature: [Signature]

4. Engineer's Representative comments:

- The proposed supplier is approved
- For all exposed installations at electrical, mechanical and service work, heavy gauge conduit with BS EN 50086 Class 4 should be used
- For false ceiling installations, light gauge conduit BS EN 50086 Class 3 should be used
- All accessories and fittings approved such as ~~box~~ circular boxes, switch and socket boxes etc.
- Flexible conduit conforms to specification and is approved.

Signature: [Signature] Date: 05/06/2018

<input type="checkbox"/>	Approved
<input checked="" type="checkbox"/>	Approved as noted
<input type="checkbox"/>	Revise and resubmit
<input type="checkbox"/>	Rejected
<input type="checkbox"/>	Sample required
<input type="checkbox"/>	Tests required
<input type="checkbox"/>	Additional information required
<input type="checkbox"/>	Manufacturer's guarantee required

Approval shall not relieve Contractor of his liabilities under the Contract or constitute authorization of any change to Contract Documents.

- Third party certificate showing compliance to BS 4568 and BS EN 50086

S-PRC-SS-02(F26) Rev 1
 - Samples to be provided and mock-up installation shall be submitted on site for approval

