

Najoie Daou  
THE RED SEA DEVELOPMENT COMPANY

Final (WF-000815) Metal Conduits RGS & Fittings - UL ...  
WORKFLOW TRANSMITTAL

YESTERDAY  
TRS03R02-WTRAN-003206



MAIL TYPE  
Workflow Transmittal

MAIL NUMBER  
TRS03R02-WTRAN-003206

REFERENCE NUMBER  
TRS03R02-WTRAN-003206

## Final (WF-000815) Metal Conduits RGS & Fittings - UL Standard ( Electrical House-ITCC )

From Najoie Daou - The Red Sea Development Company


To (9) Mr Arslan Rafique - Al kifah contracting company (+8 more...)

Cc Mr Raafat Ezzeddine - Dar Al Riyadh Engineering & Architecture

Sent Wednesday, 5 May 2021 10:47:05 PM AST (GMT +03:00)

Status N/A

### DOCUMENT ATTACHMENTS (1)

(0 selected)				
File	Document No	Revision	Title	Status
	R03-R02B01-KCC-MAT-EL-0039	00	Metal Conduits RGS & Fittings - UL Standard ( Electrical House- ITCC )	Accepted with Comments

### ATTRIBUTES

Attribute 1 Site Wide

### MESSAGE

#### Workflow Review History

The attached documents have completed the "Metal Conduits RGS & Fittings - UL Standard ( Electrical House- ITCC )" workflow with the following results :

*This transmittal was automatically generated.*

Doc No	Step	Participant	Review Outcome	Comments
R03-R02B01-KCC-MAT-	Document Control Review	W Alhaddad	Accepted	

EL-0039

LEED Review	S Perumal	Review Not Required
Supervision Consultant Review	F Abdelaty	Accepted with Comments
Electrical Review	S Gomez	Accepted with Comments
Design Manager	N Harris	Review Not Required

Approval subject to TRSDC vendor list. 1. Contractor to follow SECTION 260533 2. Contractor to submit MIR prior using on site. 3. Necessary precautions shall be taken for unloading, shifting and storage as per manufacturer recommendations.

1. Conditional acceptance provided, the contractor shall comply with all the comments and any deviation shall render the acceptance void 2. All the materials delivered to the site shall be with UL mark as detailed in the UL product IQ and materials without UL mark will be rejected, the Supervision consultant shall inspect on receipt of MIR 3. All conduit accessories and backboxes shall be from ITCC, all other accessories and backboxes will be rejected 4. The UL listed system shall be used only for Fire alarm system as agreed and shall not be used for other systems 5. All compliance shall be provided in TRSDC specification, compliance provided in third party documents are not acceptable. 6. Only rigid steel conduit shall be provided.

---

AD/PM Review

N Daou

Accepted with Comments

Refer to Technical team's  
comments.

---